

GOVERNMENT OF ARUNACHAL PRADESH

OFFICE OF THE ASSISTANT ENGINEER PUBLIC HEALTH ENGINEERING & WATER SUPPLY::

SIANG DISTRICT , AALO , ARUNACHAL PRADESH




Ref.No. ....

Dated : 08/12/2025

TO WHOM MAY CONCERN

This is to certify that SIYOM VALLEY SCHOOL, Pessing, Siang District, Aalo, Arunachal Pradesh has own arrangement of portable water for the students and members of staff of the institutions as per the site verification and submission of Annexure C Performa by site engineer.

  
Asst. Engineer 08/12/2025  
Assistant Engineer  
PHE & WS Sub Division  
Jomlo  
PHE & WS



TO WHOM IT MAY CONCERNED

No. AEJ/PHE/Cert/1046/2024-25

Dated.....08/12/2025

It is certified that an inspection team headed by Mr. Ruto Karbi, JE from PHED inspected the Siyom Valley School, Rampa, Siang district, Arunachal Pradesh on 05/12/2025 and on the basis of water test report bearing no. AEJ/PHE/WS/2020-21/288 Dated 05/12/2025 that the Siyom Valley School has safe drinking water facilities for the students and members of staff of the institution. The School is also maintains the hygienic sanitation condition in the school building & the campus as per norms by the central/ state/ U.T Govt.

This certificate is valid till Six months from the date of issue.

Signature with seal [Signature] 08/12/2025  
Assistant Engineer  
PHE & WS Sub Division  
Jomlo

Name. Tagong Taggu

Designation. Assistant Engineer

Name & Address of the office/Department. PHESD  
Jomlo

GOVERNMENT OF ARUNACHAL PRADESH  
OFFICE OF THE ASSISTANT ENGINEER  
PHE & WS SUB DIVISION:: JOMLO



Har Ghar Jal  
Jal Jeevan Mission

No. AEJ/PHE/WA/9020-21/288, Dtd 05/12/2025

WATER TESTING REPORT

BLOCK:- RUMGONG

Sl.N o.	Village	Panchayat	Habitation	Name of Source/Sche me/Delivery points	Date of Collection	Testing Date	Turbidit y NTU	PH	Total Alkalini ty mg/l	Chlorid e mg/l	Fluoride F mg/l	Nitrate as NO3 Mg/l	Total Hardness mg/l	Iron as FE mg/l	Residual Chlorine mg/l	Bacterol ogical
1	Rampa	Rampa patum	Siyom Valley school	Siyom Valley school	06-12-2025	06-12-2025	0.20	8.00	25.00	40.00	0.00	0.20	85.00	0.02	0.20	0.00

Signature

Lab Assistant

PHE & WS Sub Division  
Jomlo

Signature

Assistant Engineer  
PHE & WS Sub Division  
Jomlo